


# WESTERN ELECTRO-ACOUSTIC LABORATORY

Report No. TL11-283



1/3 OCT BND CNTR	FREQ	63	80	100	125	160	200	250	315	400	500
TL in dB		3	6	4	5	5	6	7	9	9	11
95% Confidence in dB deficiencies		1.42	1.92	2.07	1.47	0.89	0.76	0.80	0.52	0.36	0.38
								(1)	(2)	(5)	(4)
1/3 OCT BND CNTR	FREQ	630	800	1000	1250	1600	2000	2500	3150	4000	5000
TL in dB		12	13	15	17	19	21	23	24	26	28
95% Confidence in dB deficiencies		0.29	0.44	0.38	0.39	0.36	0.56	0.55	0.31	0.32	0.50
		(4)	(4)	(3)	(2)	(0)					

EWR	OITC	Specimen Area: 25.67 sq.ft. Temperature: 72.5 deg. F Relative Humidity: 52 % Test Date: 15 June 2011	STC 15 (25)
16	11		

Report must be distributed in its entirety except with written authorization from Western Electro-Acoustic Laboratory

